

CORRIGENDUM 1

Page 16

Tableau XIIA – Valeurs pour les essais de vérification du pouvoir de coupure des fusibles pour courant alternatif

Explication des symboles

Au lieu de:

I_{2a} Des temps inférieurs peuvent être choisis pour des applications spéciales.

lire:

I_{2a} Des temps inférieurs à 30 s peuvent être choisis pour des applications spéciales. Voir note de 7.4.

Page 18

Tableau XIIB – Valeurs pour les essais de vérification du pouvoir de coupure des fusibles pour courant continu

Constante de temps ^c

Au lieu de:

Lorsque le courant présumé d'essai est supérieur à 20 kA: 10 ms à 12 ms

lire:

Lorsque le courant présumé d'essai est supérieur à 20 kA: 10 ms à 15 ms

Page 17

Table XIIA – Values for breaking-capacity tests on a.c. fuses

Explanation of symbols

Instead of:

I_{2a} Shorter times may be chosen for special applications.

read:

I_{2a} Shorter times than 30 s may be chosen for special applications. See note of 7.4.

Page 19

Table XIIB – Values for breaking-capacity tests on d.c. fuses

Time constant ^c

Instead of:

Where prospective test current is greater than 20 kA: 10 ms to 12 ms

read:

Where prospective test current is greater than 20 kA: 10 ms to 15 ms